

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1597:106 Page 1 of 1

CATEGORY: Heat Detectors

LISTEE: TEPG – US, 91 Technology Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-854 Fax (978) 731-8881

DESIGN: Models 430565 and 430566 automatic, fixed temperature, rate compensated and rate of rise heat detectors. Refer to listee's data sheet for additional detailed system description and operational considerations.

RATING: 11-32 VDC
135⁰F or 200⁰F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

APPROVAL: Listed as automatic heat detectors for use with separately listed compatible fire alarm control units. Intended for use with Intended for use with separately listed Models 430569, 430570 or 430567 (CSFM Listing No. 7300-1597:107) detector bases. For indoor use only.

XLF: 7270-0026:221

04-09-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 9, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**